



**Dominion**

# **DAM INSPECTION CHECKLIST POSSUM POINT POWER STATION POND ABC**

INSPECTION DATE: 1/13/15 1331 hrs.

WEATHER: Partly cloudy, 37° F

INSPECTED BY: K. Homza / D. West

Location/ Condition	(y/n)	Change (y/n)	Comments
Low Point, A dike*			
Flow	N	N	1331 hrs. No standing water in sandbagged area.
Erosion	N	N	Sand bags + rip-rap in place.
Low Point, B dike*			
Flow	N	N	1333 hrs. No standing water. Sand bags and
Erosion	N	N	rip-rap in place.
Outfall			
water surface El. (top of stoplogs to water)			1343 hrs. 64". No discharge. A few drops of water seeping into concrete weir structure.

\* See figure below.

**Additional Comments (Note any changes observed along the embankment crest or downstream slope observed from the crest.):** Water in road cuts near "A" and "C". 0.60 inches of rain since 0200 hrs. on 1/12/15.

High tide - 1227, low tide 0546

